


EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CO0349
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräte-Richtlinie (2009/142/EG)</i>
Distributor <i>Vertreiber</i>	CHAFFOTEAUX SAS Le Carré Pleyel, 5 rue Pleyel, F-93521 St. Denis - Cedex
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing boiler with integrated burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	INOA GREEN...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, RS, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: K11862015E7 from 27.04.2015 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (01.01.2013)
File Number <i>Aktenzeichen</i>	15-0226-GEA

23.06.2015 Rie B-1/2 
 Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

Appliance Categories <i>Gerätekatategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E	20 mbar	DE, LU, PL, RO	
I2E(S)	20/25 mbar	BE	
I2Esi	20/25 mbar	FR	
I2H	20 mbar	AT, BG, CH, CZ, DK, EE, ES, FI, GB, GR, HR, HU, IE, IS, IT, LT, LV, NL, NO, PT, RO, SE, SI, SK, TR	
I2L	25 mbar	NL, RO	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
INOA GREEN 24 EU	nominal heat output: 5,3...23,0 kW heat input (Hi): 5,5...23,5 kW	
INOA GREEN 29 EU	nominal heat output: 5,8...28,4 kW heat input (Hi): 6,0...29,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Additionally tested appliance categories, supply pressures and countries of destination:

AL, CY, MK, MT, RS: I2H (20 mbar)

In Albania, Serbia and in Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania, serbia and Macedonia.

flue types: B23, B23P, B33, C13(x), C23, C33(x), C43(x), C53(x), C63(x), C83(x), C93(x) according to installation manual with flue pipes of Natalini (approval-no. Z-7.2-3338 and Z-7.2-3339) and Groppalli (approval-no. 400087 and IFPC 400009)


EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CO0349
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	CHAFFOTEAUX SAS Le Carré Pleyel, 5 rue Pleyel, F-93521 St. Denis - Cedex
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing boiler with integrated burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	INOA GREEN...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: K11862015B9 from 27.04.2015 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	15-0226-GWA

2015/04-1-EE

23.06.2015 Rie B-1/2



Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - recognized by the German Institute for Building Technology (DIBt) and notified at the European Commission as certification body for the EC Boiler Efficiency Directive

DVGW CERT GmbH - vom Deutschen Institut für Bautechnik (DIBt) nach dem Bauproduktengesetz anerkannte und bei der Europäischen Kommission benannte Zertifizierungsstelle für die EG-Heizkessel-Wirkungsgradrichtlinie

DIBt
 ZP 42

DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkenzeichnung
INOA GREEN 24 EU	nominal heat output: 5,3...23,0 kW heat input (Hi): 5,5...23,5 kW	****
INOA GREEN 29 EU	nominal heat output: 5,8...28,4 kW heat input (Hi): 6,0...29,0 kW	****

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

The energy labelling can be used according to the actual regulations of the country of destination for the individual types.
The above listed model was certified under the Product-Identnumber CE-0085CO0349 according to the Gas Appliance Directive (2009/142/EC).
